

Loren Corey Eiseley and  
Bess Jackson Wolf  
Branch Library  
Window Shade Package  
Lincoln, Nebraska

01/04

227-101 03

## ADDENDUM NO. 2

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 2-1 thru 2-2. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 2 on the Bid Proposal Form in the place provided.

### Architectural

#### Drawings

**Item 2-1: Supplemental Drawing SD-1**

Note: Contractor's Option per Shade System Mfr's requirements:

If shade system allows sufficient lead length between shade motor and motor controller, conduit, j boxes and motor controller boxes may be located above the ceiling as shown on Supplemental Drawing A-1. Note: all horizontal conduit and boxes to be located above the ceiling and not exposed. Conduit shall be exposed only where vertical runs extend to shade motor locations. Vertical conduit shall be held tight to gpdw and window frames.

**Item 2-2: Drawing Sheet E0.1**

Refer to the General Note within the box, next to the Electrical Abbreviations and Symbols Legend. Given the variance of shade systems and electrical requirements of each system, the conduit and boxes may be located as shown on Supplemental Drawing A-1 if the system allows. All horizontal conduit and boxes are to be concealed and not exposed. Conduit shall be exposed only where vertical runs extend to shade motor locations. Vertical conduit shall be held tight to gpdw and window frames.


NOTE: Shade control switch locations and windows covered per shade shall not be modified from what is documented on the drawings.

**END OF ADDENDUM NO. 2**

ADDENDUM NO. 1

ADD1 - 1






4

**WALL SECTION**

SCALE: 3/4"=1'-0"

(TYPICAL, BOTH SIDES OF CLERESTORY)



The  
Clark  
Enersen  
Partners

Architecture + Landscape Architecture + Engineering + Interiors  
1010 Lincoln Mall, Suite 200 Lincoln, NE 68508-2883  
402.477.9291 Fax 402.477.6542  
Kansas City, Missouri

Eiseley and Walt Branch Libraries Window Shades Package  
Lincoln, Nebraska  
TCEP Project No.: 227-101-03

Addendum #2  
Supplemental Drawing: A-1  
Revision of Sheet: A3  
TOTAL P.02